



S427 Purge Timers

Provide purge period to clear combustion chamber of unburned fuel prior to burner lightoff.



S427B,C



S427D

- Motor driven timers reset automatically when power is interrupted.
- Adjustable timing period.

APPROVALS:

Underwriters Laboratories Inc. Listed:
S427B,C-File No. MP2168, Guide No. MFHX;
S427D-File No. MP2168, Guide No. MFHX2.
Factory Mutual Approved: File No. 14880.1.
Industrial Risk Insurers Acceptable.
Control Safety Devices Acceptable (CSD-1).

ELECTRICAL RATINGS:

Power Supply: 120 Vac, 60 Hz.
Contact Ratings:
10A at 120 Vac;
5A at 240 Vac;
Pilot duty: 125 VA.

Available only through Honeywell Authorized Flame Safeguard Distributors.

Order Number	Application	Timing	Switching Action	Power Input	Temperature Ratings
S427B1009	General applications.	2 to 15 min.	Spdt	6.5 W max.	0 F to 125 F (-18 C to +52 C)
S427B1058		4 to 30 min.		6.5 W max.	
S427B1124		8 to 60 sec.		8.5 W max.	
S427C1008		2 to 10 min.		6.5 W max.	
S427D1007	For plug-in use in R4138.	2 to 15 min.	Dpdt	6.5 W max.	0 F to 150 F (-18 C to +52 C)
S427D1163		8 to 60 sec.		6.5 W max.	
				8.5 W max.	

EPRI Edgemont Precision Rebuilders, Inc.
Matlack Industrial Center
207 Carter Dr Unit C
West Chester, PA 19382
800 356-3774